




EIA: Wind Integration **Operation and Planning of the Electric Grid**

Casey Cathey, P.E.

Manager, Operations Engineering Analysis & Support

2015 Wind Integration Study

- *60% Wind Penetration Wind Output and Siting.*




2015 Wind Integration Study results

- The Steady-state thermal and voltage analysis confirms the need for approved ITP projects
 - Additional transmission needs beyond what was approved in the ITP process was discovered
 - Some approved ITP projects should be expedited and placed in-service sooner than the projects scheduled in-service date
- The Voltage stability analysis shows that renewable penetration levels are approaching current limits
- All N-1 constraints were resolved, albeit with substantial curtailments
- Ramping analysis indicates that in general, SPP has enough ramping capability to sustain 60% penetration


WIS - Voltage Stability Analysis

The Spring operations model (Outages)




Wind Integration Study Redispatch Analysis

Redispatched Wind




How does WIS redispatch analysis compare to actual observations from Integrated Marketplace?



*Data from 2015 Integrated Marketplace RTBM

Where does our wind power go?



*Data from 2015 Integrated Marketplace RTBM